



November 10, 2008

DE ROYAL
DAVID WATERMEIER
200 DE BUSK LANE
POWELL TN 37849

SOUTHERN MED WASTE
JAMES WHITE
1000 1/2 W COTTON
LONGVIEW TX 75604

Re: Description: HEALTH CARE PLUMBING APPLIANCE
Manufacturer: SOUTHERN MED WASTE
Product Name: AQUA-BOX(TM)
Model Number(s): 1100-00, 1200-00; 1300-00; 1300-R; 1500-00; AND 1500-R
Product File No: 20070071

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of November 2013.

This approval is contingent upon compliance with the following stipulation(s):

- The unit must be installed in accordance with the manufacturer's instructions.
- Prior to installation of this product, plans and specifications must be submitted to the department for review and approval in accordance with s. Comm 82.20 (4) of the Wis. Admin. Code. Written approval for the plans and specifications shall be obtained prior to installation of the product.
- A reduced pressure principle backflow preventer (ASSE 1013 or CAN/CSA B64.4) must be installed in the fixture supply serving this product. And be installed in accordance to Wisconsin Administrative Code 82.41 (5) (f).
- The indirect waste pipe from this product must discharge by means of an air-break or air-gap into a receptor connected to the sanitary plumbing drain system.
- The cross connection control device shall be maintained and tested in accordance to Wisconsin Administrative Code 82.21 (3).

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: Jerry.Thompson@wi.gov